

2015

Annual Drinking Water Quality Report

WALNUTPORT AUTHORITY

We're pleased to present to you this year's *Annual Drinking Water Quality Report*. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our sources are five drilled wells, four located east of the Borough of Walnutport in Lehigh Township and one located within the Borough.

Need More Information?

If you have any questions about this Report or concerning your water utility, please contact:


**Walnutport Authority
Water and Sewer**
Mr. Michael Newhard

417 Lincoln Avenue
Walnutport, PA 18088
(610) 767-7887

Public Water Supply Identification
(PWSID) Number is 3480032

We want our valued customers to be informed about their Water Utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Tuesday of every month at 7:00 p.m. at the Walnutport Borough Hall.

We look forward to continuing to serve the residents and businesses of our community.



Know the Health Risks

All sources of drinking water are subject to potential contamination by contaminants that are naturally occurring or manmade. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants.

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring materials and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:


- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791 or visiting the EPA Office of Water website at www.epa.gov/OGWDW. MCLs are set at very stringent levels for health effects.

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.

To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect. Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Walnutport Authority is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.



Impurities Detected by the Walnutport Authority

The Walnutport Authority routinely monitors for constituents in your drinking water according to federal and state laws. This table shows monitoring results for the period of January 1 to December 31, 2015. This table shows only the contaminants that were detected and the levels at which they were detected. There were many other contaminants that were not detected in the samples collected for analysis. Remember that the presence of certain constituents does not necessarily pose a health risk. All drinking water may be reasonably expected to contain at least small amounts of some constituents.

As you can see by the table, our system had no MCL violations this year. However, in the first Quarter of 2015, the Authority took samples for Synthetic Organic Contaminants. Unfortunately, the results of these analyses were submitted to the PA DEP late, and a Public Notification was issued to customers for this event. These issues have since been resolved. The remaining samples were taken, as required, and were submitted on time to the DEP.

We're proud that our drinking water meets or exceeds Federal and State requirements.

Substance	WA Detected Range	WA Highest Detected Level	Highest Level Allowed (MCL)	EPA MCLG (EPA Goal)	Sources of Contamination	Violation Y/N		
Secondary (Aesthetic) Contaminants (7/2010)								
Manganese*	0.043 - 0.049 mg/l	0.049 mg/l	0.05 mg/l	0.05 mg/l	Geology, naturally present in the environment	N		
Iron*	0 - 0.02 mg/l	0.02 mg/l	0.3 mg/l	0.3 mg/l	Geology, naturally present in the environment	N		
Inorganic Contaminants								
Nitrate	0 - 3.7 mg/l	3.7 mg/l	10 mg/l	10 mg/l	Geology, fertilizer runoff, sewage	N		
Disinfectant and Disinfection By-Products								
Chlorine (Distribution)	0.43 - 1.11 mg/l	1.11 mg/l	4.0 mg/l	4.0 mg/l	Water additive used to control microbes	N		
Haloacetic Acids (HAA5)	1.0 - 18.0 ug/l	11.3 ug/l	60 ug/l	N/A	By-product of drinking water disinfection	N		
Total Trihalomethanes (TTHMs)	2.4 - 11.9 ug/l	7.25 ug/l	80 ug/l	N/A	By-product of drinking water disinfection	N		
Bromodichloromethane (THM)	0.8 - 4.2 ug/l	4.2 ug/l	N/A	0 ug/l	By-product of drinking water chlorination	N		
Chlorodibromomethane (THM)	1.0 - 2.1 ug/l	2.1 ug/l	N/A	N/A	By-product of drinking water chlorination	N		
Chloroform (THM)	0.6 - 5.6 ug/l	5.6 ug/l	N/A	70 ug/l	By-product of drinking water chlorination	N		
Lead and Copper Rule (6/2013)								
Substance	WA Detection Range	90 th Percentile	Action Level	EPA MCLG	# of Sites Above AL of Total Sites	Violation of TT	Source of Contamination	Violation Y/N
Copper**	0.045 - 0.627 mg/l	0.348 mg/l	1.3 mg/l	0 mg/l	0 of 10	N	Corrosion of pipes, geology, wood preservatives	N

Entry Point Disinfectant Residual

Substance	Minimum Disinfectant Residual	Lowest Level Detected	Range of Detections	Date of Lowest Value	Source of Contamination	Violation Y/N
Chlorine, Location 101	0.40 mg/l	1.0 mg/l	1.0 – 1.7 mg/l	1/2/2015	Water additive used to control microbes	N
Chlorine, Location 103	0.80 mg/l	1.0 mg/l	1.0 – 1.8 mg/l	1/24/2015	Water additive used to control microbes	N
Chlorine, Location 105	0.70 mg/l	1.0 mg/l	1.0 – 1.8 mg/l	8/25/2015	Water additive used to control microbes	N

Notes:

The PA DEP allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Items not sampled for in 2015 are noted with the last year of sampling.

*Manganese and Iron are regulated by a secondary maximum contaminant level (MCL), a standard which was established to address issues of aesthetics (discoloration), not health concerns.

** The Action Level (AL) for Lead and Copper serves as a trigger for water systems to take additional treatment steps if exceeded in more than 10% of tap water samples. The Action Level for Lead is 15 ug/L, and the Action Level for Copper is 1.3 mg/L. No Action Levels were exceeded in the 2013 sampling, and Lead was not detected during the 2013 sampling.

Definitions

In the tables in this report you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level (AL)

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

MCL - Maximum Contaminant Level

The "Maximum Allowed" is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

mg/l - Milligrams per liter or Parts per million (ppm)

One milligram per liter or one part per million (ppm) corresponds to one minute in two years or a single penny in \$10,000.

MCLG - Maximum Contaminant Level Goal

The "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MRDL - Maximum Residual Disinfectant Level

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG - Maximum Residual Disinfectant Level Goal

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

pCi/l - Picocuries per liter

Picocuries per liter is a measure of the radioactivity in water.

ug/l - Micrograms per liter

One microgram per liter corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.



We at the Walnutport Authority work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Thank you for allowing us to continue providing your family with clean, quality water this year. In order to maintain a safe and dependable water supply, we sometimes need to make improvements that will benefit all of our customers. These improvements are sometimes reflected as rate structure adjustments. Thank you for understanding.

Este informe contiene información muy importante sobre su agua potable.

Tradúzcalo ó hable con alguien



Undetected Impurities Tested for by Walnutport Authority

Inorganic Chemicals (1/2015)

Antimony
Arsenic
Asbestos (3/2012)
Barium
Beryllium
Cadmium
Chromium
Cyanide (Free)
Fluoride
Lead (2013)
Mercury
Nickel
Nitrite
Selenium
Thallium

Disinfection By-Products

Bromoform (THM)

Synthetic Organic Chemicals (2015)

Alachlor
Atrazine
2,4 - D
2,4,5 - TP Silvex
1,2 dibromo, 3-chloroprop
2,3,7,8-tcdd (Dioxin)
Benzo(a)pyrene
Carbofuran
Chlorodane
Dalphon
Di (2-ethylhexyl) adipate
PCB's
18 Other SOC's

Volatile Organic Chemicals (2015)

1,1,1-Trichloroethane
1,1,2-Trichloroethane
1,1-Dichloroethylene
1,2,4-Trichlorobenzene
1,2-Dichloroethane
1,2-Dichloropropane
Benzene
Carbon tetrachloride
Chlorobenzene
cis-1,2-Dichloroethylene
Dichloromethane
Ethylbenzene
o-Dichlorobenzene
Methyl-Tert-Butyl-Ether
para-Dichlorobenzene
Styrene
Tetrachloroethylene
Toluene
trans-1,2-Dichloroethylene
Trichloroethylene
Vinyl chloride
Xylenes (Total)

Microbiological Contaminants

Total Coliforms

Radiologicals (2015)

Combined Uranium
Gross Alpha
Gross Beta
Radium (226 & 228)

Notes: *Contaminants in Italics Not Regulated by EPA.*

Not all contaminants are sampled for every year, according to DEP regulations. Those contaminants not sampled for in 2015 are noted with the last month and year of sampling.